

1 10A NCAC 13S .0211 is proposed for adoption under temporary procedures as follows:

2  
3 **10A NCAC 13S .0211 DOORS**

4 Minimum width of doors to all rooms needing access for stretchers shall be three feet. No door shall swing into  
5 corridors in a manner that might obstruct traffic flow or reduce the required corridor width except doors to spaces not  
6 subject to occupancy.

7  
8 History Note: Authority 131E-153; 131E-153.5; 143B-165.  
9